

Blackfoot Drainage Ditch - Baseline Water Quality Test

Parameter	Units	Federal (WSER) Limits	Blkft Lagoon			Location 5			Location 6			Location 8	Location 9	Location 10
			16-09-20	12-11-09	21-10-14	15-10-08	16-04-27	16-08-24	15-10-08	16-04-27	16-08-24	16-08-24	22-12-04	22-12-04
BOD	mg/L	25	5	5	7	24	6	10	14	6	7	4	53	13
TSS	mg/L	25	8	7	25	354	48	63	96	32	263	197	8,000	19
Ammonia-N (un-ionized)	mg/L	1.25	-	-	-	<0.01	<0.01	<0.01	<0.01	<0.01	0.01	<0.01	0.004	0.001

Acronym	Definition
BOD	Biological Oxygen Demand
TSS	Total Suspended Solids
WSER	Wastewater Systems Effluent Regulations

